

BRISTOL WATER DEPARTMENT WATER QUALITY REPORT



**Bristol Water Dept.
William Bryant
Town Administrator
Town of Bristol
P.O. Box 249
Bristol, VT 05443
802-453-2410**

Selectboard meetings are held on every other Monday at 7 PM in the municipal offices at Holley Hall.

January - December 2010

The purpose of this report is to satisfy the EPA and DEC requirements for Consumer Confidence Reporting. Although some of the items may not be of interest to you personally, we feel that this is an important aspect of our overall commitment to supply you with the safest quality drinking water possible.

Terms to Become Familiar With:

Maximum Contaminate Level (MCL): This is the highest allowable level of contaminant in drinking water. MCLs are set as close to MCLGs as feasible using the best available technology.

Maximum Contaminate Level Goals (MCLGs): These goals are set at levels that are below where there is no known health risk. MCLGs are considered a margin of safety.

PPM: Parts per million or mg/L.

PPB: Parts per billion.

Action Level: The concentration of a contaminant, which, if exceeded, triggers treatment, or other requirements that a water system must follow.

90th Percentile: Ninety percent of the samples are below the action level. (Nine of ten sites' samples were at or below this level.)

Health Information Regarding Drinking Water:

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants, can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from EPA's Safe Drinking Water Hotline (1-800-426-4791).

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Safe Drinking Water Hotline.

Bristol Water Department is classified and permitted as a groundwater, non-purchased water system, operating under water system identification #5002

Water is supplied for Bristol Water Department by an approved ground water source, which is New Haven Spring.

Simon Operation Services, Inc. Your Water Professionals

Simon Operation Services, Inc. (SOS) became responsible for the operation of the system in June 2009. SOS's staff includes these certified operators: Lance Perlee & Kevin Knapp.

A Source Protection Plan (SPP) for the Bristol Water Department's water supply system was updated in April 2009. A copy of the SPP is on file with the Bristol Water Department. Information on the vulnerability of the water supply to contamination (Possible Sources of Contamination) is found in the approved SPP. Improperly maintained septic systems and proximity to roadways may be possible sources of contamination.

SOS prepared this report. If you have any questions about Bristol Water Department's water quality, call 1-888-767-1885 or email us at SimonOp@aol.com.

COMPLIANCE: This report is a snapshot of the quality of water that we provided for the year 2010. It also includes the date and results of any contaminants that were detected within the past five years tested less than once a year. Any contaminants detected within the past five years are listed along with the date of detection and concentration.

No violations occurred during 2010.

| <u>Contaminants</u> | <u>Level Detected</u> | <u>MCL</u> | <u>MCLG</u> | <u>Sample Date</u> |
|---------------------|-----------------------|------------|-------------|--------------------|
| Nitrate | 0.43 ppm | 10.000 | 10.000 | 6/17/2010 |

Possible Sources of Contamination

Nitrate – runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.

Copper and Lead – corrosion of household plumbing systems; erosion of natural deposits.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Bristol Water Department is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-802-426-4791) or at <http://www.epa.gov/safewater/lead>.

Public Notice – Uncorrected Significant Deficiencies:

Date Identified : 8/28/08

- Inadequate Cross-Connection Controls (CT VESSEL)

Sources of Drinking Water and Contaminants

The sources of drinking water (both tap water and bottled water) include surface water (streams, lakes) and ground water (wells, springs). It also picks up substances resulting from human activity and from animals. Some “contaminants” may be harmful. Others, such as iron and sulfur, are not harmful. Public water systems treat water to remove contaminants if they are present.

In order to ensure that your water is safe to drink, we test it regularly according to regulations established by the U.S. Environmental Protection Agency and by the State of Vermont. These regulations limit the amount of various contaminants:

- *Microbial organisms* (viruses and bacteria) may come from sewage treatment facilities, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic chemicals* (salts and metals) can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, or farming.
- *Synthetic Organic chemicals* (pesticides and herbicides) may come from agriculture, urban storm water runoff, residential uses, and careless disposal of household chemicals.
- *Volatile Organic chemicals* (gasoline and solvents) may come from gas stations, urban storm water runoff, septic systems, industrial processes, and careless disposal of household chemicals.
- *Naturally occurring radioactivity*

Lead and Copper Action Levels

| <u>Contaminant Detected</u> | <u>Action Level</u> | <u>90th Percentile</u> | <u>Sampling Date</u> | <u># of Sites that Exceeded the Action Level</u> | <u>Total # of Sites Sampled</u> |
|-----------------------------|---------------------|-----------------------------------|----------------------|--|---------------------------------|
| Copper | 1.3 ppm | 0.20 | 2010 | 0 | 10 |
| Lead | 15 ppb | 2.00 | 2010 | 0 | 10 |

Temporary Operating Permit Public Notice

The Bristol Water Department (the Water System), a public water system under the laws of the State of Vermont, was reissued a Temporary Operating Permit on December 23, 2008. The Secretary of the Agency of Natural Resources found that such issuance will not unreasonably contribute to a public health risk, although the Bristol Water Department does not presently comply with certain requirements of the Federal Safe Drinking Water Act and applicable state statutes and rules. The nature and extent of the noncompliance are as follows:

The Water System does not provide adequate disinfection contact time for its supplementary disinfection system or adequate cross-connection controls to meet the requirements of the Vermont Water Supply Rule. The Water System is following through on specific recommendations made by the Water Supply Division to eliminate potential sanitary hazards and provide for future system durability and reliability. In accordance with the Vermont Water Supply Rule, the Division has requested the timely resolution of all water system deficiencies. To obtain more specific information regarding these necessary public drinking water improvements, please call Lance Perlee of Bristol Water Department at (802) 453-2410.