

Bristol Town Administrator

From: Collins, Heather <Heather.Collins@vermont.gov>
Sent: Thursday, February 14, 2019 2:03 PM
To: Jill Marsano; Bristol Town Administrator
Subject: RE: Sanitary Survey Letter for 5002 Bristol Water Dept.

Hi Jill,

Thank you for the photo. The proposal for the stainless steel pans is acceptable to the Division. This photo is helpful as it demonstrates the need of a solid surface above the finished water as the tools and parts in this photo could easily fall through the grating into the finished water below.

Please send me photos once the pans have been installed to resolve this deficiency.

Thank you!

Heather Collins
System Operations Specialist
Phone (802) 461-3722
Fax (802) 828-1541
heather.collins@vermont.gov



Agency of Natural Resources
Department of Environmental Conservation
Drinking Water and Groundwater Protection Division
1 National Life Drive - Main 2
Montpelier VT 05620-3521

Note: Written communications to and from state officials regarding state business are considered public records and will be available to the public for review.

From: Jill Marsano <jill@vtums.com>
Sent: Thursday, February 14, 2019 1:49 PM
To: Collins, Heather <Heather.Collins@vermont.gov>; Bristol Town Administrator <townadmin@bristolvt.org>
Subject: Re: Sanitary Survey Letter for 5002 Bristol Water Dept.

Heather,

As we just discussed over the phone, here is a picture of the concrete edge that is higher than the top of the yellow grating.



Jill M.

Get [Outlook for iOS](#)

From: Collins, Heather <heather.collins@vermont.gov>
Sent: Thursday, February 14, 2019 1:36 PM
To: Bristol Town Administrator
Cc: Jill Marsano
Subject: RE: Sanitary Survey Letter for 5002 Bristol Water Dept.

Good afternoon Valerie and Jill,

I have reviewed the proposal for the catwalk and reviewed the photos I took during the survey.

The pan construction and material sounds like it would meet the intent of Appendix A, Part 7.0.15 of the Rule, *“Internal catwalk: Every catwalk over finished water in a storage structure shall have a solid floor with raised edges so designed that shoe scrapings and dirt will not fall into the water.”*; however, I am not clear on whether the catwalk as currently constructed provides a raised edge on the concrete toward the left of the catwalk as you walk in the doorway. I’ve circled the area I’m referring to in the attached photo. If this area is not raised then perhaps Avonda can provide some sort of angle iron type of material that can be bolted to the concrete that provides a raised edge?

Feel free to give me a call if you have any questions,

Heather Collins
System Operations Specialist
Phone (802) 461-3722
Fax (802) 828-1541
heather.collins@vermont.gov



Agency of Natural Resources
Department of Environmental Conservation
Drinking Water and Groundwater Protection Division
1 National Life Drive - Main 2
Montpelier VT 05620-3521

Note: Written communications to and from state officials regarding state business are considered public records and will be available to the public for review.

From: Bristol Town Administrator <townadmin@bristolvt.org>
Sent: Wednesday, February 13, 2019 12:33 PM
To: Collins, Heather <Heather.Collins@vermont.gov>
Cc: Jill Marsano <info@vtums.com>
Subject: Re: Sanitary Survey Letter for 5002 Bristol Water Dept.

Thanks, Heather!

--Valerie

Valerie Capels, Town Administrator
Town of Bristol
1 South Street
P.O. Box 249
Bristol, VT 05443
P: (802) 453-2410 ext. 22
E: townadmin@bristolvt.org
W: www.bristolvt.org
FB: <https://www.facebook.com/bristolvt/>
Tw: @BristolTownAdm

From: Collins, Heather <Heather.Collins@vermont.gov>
Sent: Wednesday, February 13, 2019 11:59 AM
To: Bristol Town Administrator
Cc: Jill Marsano
Subject: RE: Sanitary Survey Letter for 5002 Bristol Water Dept.

Hi Valerie,

I'd like to run the proposal by our Engineering section first and get their input. I'm in the office all day tomorrow and will try and schedule a meeting to look it over with them.

Thanks,

Heather Collins
System Operations Specialist
Phone (802) 461-3722
Fax (802) 828-1541
heather.collins@vermont.gov



Agency of Natural Resources
Department of Environmental Conservation
Drinking Water and Groundwater Protection Division
1 National Life Drive - Main 2
Montpelier VT 05620-3521

Note: Written communications to and from state officials regarding state business are considered public records and will be available to the public for review.

From: Bristol Town Administrator <townadmin@bristolvt.org>
Sent: Wednesday, February 13, 2019 11:52 AM
To: Collins, Heather <Heather.Collins@vermont.gov>
Cc: Jill Marsano <info@vtums.com>
Subject: Re: Sanitary Survey Letter for 5002 Bristol Water Dept.

Hi Heather,

Have you had a chance to review the proposal for the chlorine contact tank platform? If it's acceptable, we would like to get moving on that. Please let us know if you need any other information.

Thanks,

--Valerie

Valerie Capels, Town Administrator
Town of Bristol
1 South Street
P.O. Box 249
Bristol, VT 05443
P: (802) 453-2410 ext. 22
E: townadmin@bristolvt.org
W: www.bristolvt.org
FB: <https://www.facebook.com/bristolvt/>
Tw: @BristolTownAdm

From: Collins, Heather <Heather.Collins@vermont.gov>
Sent: Monday, February 4, 2019 4:43 PM
To: Bristol Town Administrator
Subject: RE: Sanitary Survey Letter for 5002 Bristol Water Dept.

Thank for the expeditious response Valerie. I will look these over tomorrow and let you know if I have any questions.

Thanks and have a nice evening,

Heather Collins
System Operations Specialist
Phone (802) 461-3722
Fax (802) 828-1541
heather.collins@vermont.gov



Agency of Natural Resources
Department of Environmental Conservation
Drinking Water and Groundwater Protection Division
1 National Life Drive - Main 2
Montpelier VT 05620-3521

Note: Written communications to and from state officials regarding state business are considered public records and will be available to the public for review.

From: Bristol Town Administrator <townadmin@bristolvt.org>
Sent: Monday, February 4, 2019 4:31 PM
To: Collins, Heather <Heather.Collins@vermont.gov>
Cc: Jill Marsano <info@vtums.com>; Rick Chaput <vrchaput@gmail.com>; Smart, Patrick <Patrick.Smart@vermont.gov>; Galford, Amy <Amy.Galford@vermont.gov>; P2 Environmental <beaves@sover.net>; Mary Blacklock Jackman <mary@addisontrust.org>; Cyrus Marsano <cymarsano@comcast.net>
Subject: RE: Sanitary Survey Letter for 5002 Bristol Water Dept.

Hi Heather,

Please find attached the Town of Bristol's response to your sanitary survey letter of January 7, 2019. Please let us know if you need any other information.

Thank you,

--Valerie

Valerie Capels, Town Administrator
Town of Bristol
1 South Street
P.O. Box 249
Bristol, VT 05443
P: (802) 453-2410 ext. 22
E: townadmin@bristolvt.org
W: www.bristolvt.org
FB: <https://www.facebook.com/bristolvt/>
Tw: @BristolTownAdm

From: Collins, Heather <Heather.Collins@vermont.gov>
Sent: Monday, January 7, 2019 3:26 PM
To: Bristol Town Administrator <townadmin@bristolvt.org>
Cc: Jill Marsano <info@vtums.com>; Rick Chaput <vrchaput@gmail.com>; Smart, Patrick <Patrick.Smart@vermont.gov>; Galford, Amy <Amy.Galford@vermont.gov>; P2 Environmental <beaves@sover.net>; Mary Blacklock Jackman <mary@addisontrust.org>
Subject: Sanitary Survey Letter for 5002 Bristol Water Dept.

Good afternoon Ms. Capels,

Please find the attached Sanitary Survey Letter for 5002 Bristol Water Dept.

Included at the end of the letter for your review is a discussion regarding the consecutive system Kilbourn MHP. The Bristol Water department has expanded its distribution system over the years and Kilbourn MHP is located within the distribution system, not on a dead-end service line. The Division has copies of the Kilbourn

MHP distribution line replacement project drawings from 2004 should the Wholesaler wish to review these drawings for consideration of absorbing the MHP as it has done with Woodland Apartments.

Please don't hesitate to contact me if you have any questions,

Heather Collins

System Operations Specialist

Phone (802) 461-3722

Fax (802) 828-1541

heather.collins@vermont.gov



Agency of Natural Resources

Department of Environmental Conservation

Drinking Water and Groundwater Protection Division

1 National Life Drive - Main 2

Montpelier VT 05620-3521

Note: Written communications to and from state officials regarding state business are considered public records and will be available to the public for review.